


3rd International Hybrid Power Systems
Workshop


May 8-9, 2018
Tenerife, Spain



**EVALUATION OF THE IMPACT OF INTRA-DAY
DISTRIBUTED PV AND WIND GENERATION
FORECASTS ON DECISION-MAKING IN THE
OPERATIONS OF AN ISLAND GRID SYSTEM**

John W Zack, Ph.D.
UL AWS Truepower
463 New Karner Rd
Albany, NY
jzack@awstruepower.com

Robert Kaneshiro and Lisa Dangelmaier
Hawaii Electric Light Company (HELCO)
Hilo, Hawaii
robert.kaneshiro@hawaiielectriclight.com

 **AWS TRUEPOWER** UL and the UL logo are trademarks of UL LLC © 2017. Proprietary & Confidential.

OVERVIEW

Objective: Develop and apply a forecast performance metric that provides a meaningful indication of the value of wind and solar forecasts to operational grid management decision-making

- System Overview: [Hawaii Electric Light Company \(HELCO\) – Big Island](#)
- Some Key Daily Operational Decisions Impacted by Renewable Generation
- Case Examples: Morning Peak Load Issues
- Traditional vs. Customized & Targeted Forecast Evaluation


BIG ISLAND/HELCO - THE CURRENT ISSUES: KILAUEA ERUPTS...



AWS TRUEPOWER UL and the UL logo are trademarks of UL LLC © 2017. Proprietary & Confidential.

3

HELCO SYSTEM: GENERATION RESOURCES




Renewable Resource	Capacity
Geothermal	38 MW
Hydro (3 gens)	16.2 MW
Wind (2 gens)	31 MW
PV (BTM distributed)	90 MW

Base 24-hr Units
Hill 5 & 6 Steam Units
Keahole 1st CT in combine cycle (CC)
PGV (Geothermal)
Intermediate Units
Keahole 2 nd unit in CC
HEP 1 st and 2 nd in CC
Peaking/Emergency Units
Kanoelehua CT-1
Keahole CT-2
Puna CT-3
Puna Steam Unit
12 Small Diesel Generators
As Available - Must Take
HRD Wind Farm (10.5 MW)
Pakini Nui Wind Farm (20.5 MW)
Waialuku Hydro (12 MW)
Puueo Hydro (3.1 MW)
Waiau Hydro (1.1 MW)

AWS TRUEPOWER UL and the UL logo are trademarks of UL LLC © 2017. Proprietary & Confidential.


4

HELCO: TYPICAL LOAD PROFILES




NET LOAD

- Weekday Net load: 2 daily peaks
 - Morning (~0800): 130-140 MW
 - Morning rise in gross load followed by morning rise in PV production
 - Evening (~1800): 170-180 MW
- Weekday Net load: 2 daily minima
 - Nighttime (~0300): 95-105 MW
 - Daytime (~1200): 115-125 MW
 - Associated with peak of 35-40 MW of distributed PV production




GROSS LOAD



BTM PV

KEY DECISION-MAKING TIME FRAMES AND ISSUES

- 0500 HST: Preparation for morning peak and mid-day minimum
- 1000 HST: Midday net load ramps
- 1300 HST: Preparation for evening peak



MORNING (0500 HST) DECISION-MAKING PERIOD

• System Management Issues


- Will mid-day net loads be low enough to shutdown a unit after the morning peak?
 - If YES: simple cycle CT that has no start/stop restrictions but less efficient can be used to serve the morning peak then shutdown when no longer needed.
 - If NO: more efficient combine cycle (CC) CT will be used throughout the day
 - One CC plant has a start/stop restriction: no multiple starts in a calendar day
- Will an excess energy situation occur due to high “as available” generation?
 - Determine whether curtailment of the as-available renewable generation OR taking a unit offline will best address the situation

• Critical Forecast Questions

- Will the distributed solar generation rise to its typical midday values or higher or will there much below normal solar generation?
- Will the wind generation increase or decrease from its pre-sunrise level and thus either contribute to or offset a potential excess energy situation?

WIND AND SOLAR FORECAST SYSTEM: SWIFT


Example of a SWIFT Forecast Display



- Forecasts are produced from an ensemble of prediction-methods (physics-based and statistical)
- Two Forecast Time Frames
 - Intra-day
 - 0-6 hrs ahead in 15-min time steps
 - 15-min updates
 - Multiple Day
 - 0-7 days ahead in 1-hr time steps
 - 1 hr updates
- Probabilistic Format
 - 10 Probability of Exceedance (POE) values
 - 50% POE used as deterministic forecast
- Target Entities
 - Utility-scale PV & wind generation facilities
 - Substation aggregates of distributed PV
 - Regional and system (island) aggregates

CASE EXAMPLE #1: OCTOBER 24, 2017 HIGH DAYTIME NET LOAD

Hot, humid, cloudy & very light winds




- Unusually high mid-day gross load
 - Warm and humid -> high AC load
 - Not anticipated – no weather dependent load forecast available
- Very low distributed PV production
 - Much more cloudiness than typical
 - SWIFT indicated a cloudy day but underestimated magnitude
- Near-zero wind production
 - Was near zero before sunrise and remained at that level
 - SWIFT predicted a rise in wind production that did not happen

OUTCOME: system had to rely on less economical fast starting simple cycle combustion turbines and quick start diesels. Had high net loads been anticipated, a combine cycle combustion turbine would have been utilized

CASE EXAMPLE #2: MARCH 19, 2017 EXTREMELY LOW DAYTIME NET LOADS

Cool, clear & increasing wind




- Daytime minimum (85 MW) was below nighttime minimum (100 MW)
- Low mid-day gross load
 - Cool and dry conditions
- Very high distributed PV production
 - Almost 60 MW at mid-day,
 - SWIFT accurately forecasted this
- Wind production had sig morning increase
 - 15 MW increase: 0500 -> midday
 - SWIFT accurately forecasted this

OUTCOME: Based on the forecasted high PV and increasing wind production operator took a combine cycle unit offline to avoid curtailment of the as-available renewable generation

CASE EXAMPLE #3: FEBRUARY 7, 2017 LARGE MORNING DECREASE IN WIND PRODUCTION

Warm, hazy and decreasing winds




- Typical mid-day gross load
- Typical morning rise in PV production
 - 35-40 MW
 - Well forecasted by SWIFT
- Significant decrease in wind production
 - -16 MW change: 0500 -> late morning
 - SWIFT erroneously predicted a continuation (i.e. no change) of the relatively high pre-sunrise wind production


OUTCOME: Wind forecast error caused stress but fortunately the operator was able to start a combine cycle unit early enough and had fast start units available to handle the change in wind generating capability.

2017 TRADITIONAL FORECAST EVALUATION: MORNING DECISION PERIOD (0500-1100 HST)

Solar Power Forecast: Mean Absolute Error




Wind Power Forecast: Mean Absolute Error




But how useful is the forecast information in the morning decision-making process?

ALTERNATIVE FORECAST EVALUATION: DECISION-RELEVANT CATEGORIES

2017 Variability Distribution:
Morning (08-11) Increase in PV Production



2017 Variability Distribution:
Morning (05-11) Change in Wind Generation



Cat Label	Solar Event (08-11 HST)
S1	PV ramp rate sig below normal
S2	PV ramp rate in normal range
S3	PV ramp rate sig above normal

Cat Label	Wind Event (05-11 HST)
W1	Wind gen significantly decreases
W2	No significant change
W3	Wind gen significantly increases

CATEGORY-BASED EVALUATION SYSTEM: BASIC

Category #	Forecasted			
	Category	Below	Typical	Above
Observed	Below	1	2	3
	Typical	4	5	6
	Above	7	8	9

- Ratios of Correct and Incorrect Outcomes
 - Hits (H) = Cat #1 + Cat #9
 - Misses (M) = Cat #2 + Cat #3 + Cat #7 + Cat #8
 - False Alarms (FA) = Cat #4 + Cat #7 + Cat #3 + Cat #6
 - Critical Success Index (CSI) = $H / (H + M + FA)$
- Issues
 - Does not account for multiple category errors
 - Does not consider relative frequency of outcomes: could provide hedging incentive
 - Does not weight relative cost of errors
 - Does a miss of a "below" event cost the same as a miss of an "above" event?
 - Is the cost of a "miss" the same as a "false alarm"?

CATEGORY-BASED EVALUATION SYSTEM: ADVANCED

- General Skill Score (GS)
 - Measures skill relative to a random forecast of categories considering the relative frequencies of outcomes (0= same as a random forecast, 1= perfect)
 - Can be formulated to have relative weighting for errors
 - All of this accomplished through a scoring matrix: s_{ij}

$$GS = \frac{1}{N} \sum_{i=1}^K \sum_{j=1}^K n(F_i, O_j) s_{ij}$$

N = Total # of fcst-outcome pairs
 n(F,O) = # of pairs in each fcst-outcome bin
 S = Scoring matrix (score for each bin)
 K = # of forecast categories

- Example of a Scoring Matrix (s_{ij})
 - Based on a 10%, 80%, 10% (below, typical, above) frequency of outcomes
 - 2-category errors are penalized twice as much as a 1-category errors
 - All other errors have the same weighting (misses, false alarms etc.)


SCORING		Forecasted		
		Category	Below	Typical
Observed	Below	1	-4	-1
	Typical	0	1	0
	Above	-1	-4	1



UL and the UL logo are trademarks of UL LLC © 2017. Proprietary & Confidential.

15

ALTERNATIVE FORECAST EVALUATION: 2017 CATEGORY-BASED SOLAR PERFORMANCE



- Ratios: CSI=37.3%
 - Hits are 37% of observed and forecasted events

Ratios	H	M	FA	Total	CSI
Below	4	27	1	32	12.5%
Above	24	8	11	43	55.8%
Total	28	35	12	75	37.3%

- General Skill Score: GS=39.1%
 - 39% of the way from random to perfection


COUNT		Forecasted			Obs Freq
		Category	Below	Typical	
Observed	Below	4	27	0	10.1%
	Typical	1	232	11	79.5%
	Above	0	8	24	10.4%
	Fore Freq	1.6%	87.0%	11.4%	100.0%

GS	F-Below	F-Typical	F-Above	Sum
O-Below	4	-108	0	-104
O-Typical	0	232	0	232
O-Above	0	-32	24	-8
Sum	4	92	24	120
Total Cases				307
GS				39.1%



16

ALTERNATIVE FORECAST EVALUATION: 2017 CATEGORY-BASED WIND PERFORMANCE



COUNT	Forecasted				
	Category	Down	No Change	Up	Obs Freq
Observed	Down	4	29	0	10.3%
	No Change	13	243	3	80.7%
	Up	2	27	0	9.0%
	Fore Freq	5.9%	93.1%	0.9%	100.0%

- Ratios: CSI=5.0%
 - Hits are 5% of observed and forecasted events

Ratios	H	M	FA	Total	CSI
DOWN	4	29	15	48	8.3%
UP	0	29	3	32	0.0%
Total	4	58	18	80	5.0%

- General Skill Score: GS=6.5%
 - 6.5% of the way from random to perfection

GS	F-Down	F-Typical	F-Up	Sum
Obs-Below	4	-116	0	-112
Obs-Typical	0	243	0	243
Obs-Above	-2	-108	0	-110
Sum	2	19	0	21
Total Cases				321
GS				6.5%



17

SUMMARY

- Identified the key operating decisions and time frames of the Hawaii Electric Light Co (HELCO) system that are dependent on wind and solar variability
- Formulated a customized categorical forecast evaluation scheme to measure the aspects of forecast performance that are critical to decision-making
- Developed a customized but structurally similar categorical scheme for each type of key operational decision-making situation (morning peak, mid-day net load ramps etc)
- Designed and implemented a customized categorical forecast performance metric
- Results:
 - Traditional forecast metrics (e.g. MAE, RMSE) indicate the wind and solar forecasts for the HELCO system achieve state-of-the-art forecast performance
 - Customized Category-based metrics based operational decision-making scenarios indicate that forecasts are biased to the prediction of typical conditions and do not have adequate skill in forecasting operationally significant atypical conditions
- Next steps: Optimize forecast systems to achieve best performance for customized category-based metrics (i.e. predicting atypical conditions)



UL and the UL logo are trademarks of UL LLC © 2017. Proprietary & Confidential.

18